



EAST CALN TOWNSHIP

Chester County, Pennsylvania
110 Bell Tavern Road Downingtown, PA 19335
Office: 610-269-7326 Fax: 610-269-9183

Fire Alarm Inspection and Post-Installation Guide

The following inspections are required for all new fire alarm or detection systems. Any existing fire alarm or detection system that is modified, repaired, has system components added or removed, or has any other changes to wiring or hardware shall also require these inspections.

1. Proper instructions given to customer on use of system
2. Copy of instruction manual and/or owner's manual on site
3. "As-Built" Record drawings and specifications
4. Copy of Site-specific software on site
5. Documentation of Acceptance Testing per NFPA 72
6. Written Record of Completion per NFPA 72
7. Final Inspection/Testing witnessed by East Caln Township Fire Marshal or Building Official.

Fire Alarm and Detection systems shall be designed and installed in accordance with the following codes that are in effect in East Caln Township:

- 2009 International Building Code
- 2009 International Fire Code
- 2009 International Mechanical Code
- NFPA 72, 2007 Edition
- East Caln Township Local Code and Ordinances

Questions can be directed to the Office of Life Safety & Code Enforcement at 610-269-7326.